



Purchasing Division

## ADDENDUM NO. 1

**DATE:** January 8, 2019  
**FROM:** City of Grand Junction Purchasing Division  
**TO:** All Offerors  
**RE:** Investigation and Repair of Outlet Control Valves at Juniata Reservoir  
RFP-4591-19-DH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Q. The scope of services described in RFP section 4.3 calls for a "physical de-scaling of the tuberculated valve stems, and valve seat area". In order to quantify task times for the cost estimate, can the City define the cleaning criteria (such as a Rubert gauge of roughness)? This will allow bidding contractors to more competitively develop the bid price.

A. The Contractor is required to remove the existing tuberculation from the mid-level and low-level valve stems and valve seat areas. The City's criteria is to have the Contractor remove the tuberculation and expose a clean steel surface. The City is not requiring a certain Rubert Gauge of Roughness be achieved. Once tuberculation is removed and a clean steel surface is achieved, the City will operate the valve(s) to see if removal of the tuberculation has improved the valves operation and sealing capabilities.

2. Q. Can you advise if there a secondary valve downstream of the inlet valves at the outlet structure or somewhere in between?

A. Yes, there are existing butterfly valves (secondary valves) located downstream of the outlet control valves that are to be worked on as part of this investigation and repair project. These secondary butterfly valves were installed in 2002 and are in good working condition. These secondary butterfly valves are located on the downstream face of the Juniata dam and are within concrete vault structures.

3. Q. Are there any pictures of the outlet control structure?

A. No.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

A handwritten signature in black ink, appearing to read "Duane Hoff Jr.", is written over a white background.

Duane Hoff Jr., Senior Buyer  
City of Grand Junction, Colorado