

Purchasing Division

ADDENDUM NO. 1

DATE: September 23, 2022

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: IFB-5116-22-DD 2022 Safe Routes to School – Elm Avenue

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. Question: What does the tree trimming bid item include?

Answer: Tree trimming shall be performed by a licensed tree service to provide 8 feet of clearance above the sidewalk. If toots are encountered during construction that are greater than 3 inches in diameter, the Contractor shall inform the Project Engineer before proceeding with excavation activities.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

Dolly Daniels, Senior Buyer

Song Sanie bo

City of Grand Junction, Colorado