

## **Purchasing Division**

## **ADDENDUM NO. 2**

DATE: September 26, 2022

FROM: City of Grand Junction Purchasing Division

TO: All Offerors

RE: Professional Civil Engineering Services for Water and Wastewater Pipeline Replacement

Projects RFP-5112-22-KH

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

1. **Q:** Regarding the above referenced RFP, the original solicitation calls for a fee schedule under Section 5.0 paragraph E.

"Fee Proposal: Provide a complete list of all potential costs with associated services, as may be related to civil engineering design services. The list should be broken down into both hourly rates, and flat rate fees, as may apply"

In the addendum (questions 3) there is new discussion regarding providing a fee proposal for a particular task that is 7000 feet of 6-inch waterline and 24,000 feet of 8-inch sewer line. There is no detail regarding this project task, such as if this is replacement lines or new construction or an upgrade, in pavement, utility conflicts, number of connections etc. The addendum appears to indicate this is a clarification of the original request, but I don't see anything it the original solicitation that pertains to this. I am also unclear if this is 2 separate tasks, and you would want 2 fee proposals or if it is combined.

Please clarify if the addendum is adding a new requirement to the solicitation and provide some details to allow us to put together a scope of work and associated fee and clarify if you want this two separate fees or a combined fee.

**A:** In the headers to the response to questions, it was noted that these were both replacement projects. Assume in pavement. Potential for utility conflicts that would have been to determine by the engineer via SUE. Number of connections TBD but can assume 20 per 700 feet of line for both water and sewer. Please provide fees for 3 separate projects: 1) waterline replacements, 2) sewer line replacements, 3) sewer capacity project.

The original solicitation for the project noted above is amended as noted.

All other conditions of subject remain the same.

Respectfully,

Kassy Hackett, Buyer

City of Grand Junction, Colorado