



Purchasing Division

ADDENDUM NO. 3

DATE: November 28, 2023
FROM: City of Grand Junction Purchasing Division
TO: All Offerors
RE: 2023 Sewer Replacements Pases 6, 8, & 10 Open Cut

Offerors responding to the above referenced solicitation are hereby instructed that the requirements have been clarified, modified, superseded, and supplemented as to this date as hereinafter described.

Please make note of the following clarifications:

- 1. Question:** If bypass pumping takes place 24 hours a day, will the pump need to be manned and monitored during non-working works?
Answer: If bypass pumping is turned off at night, then no one is needed on site at night. Only during bypass pumping.
- 2. Question:** Just to verify, there is no coating on the manholes, correct?
Answer: There is no coating on the manholes.

The original solicitation for the project noted above is amended as noted. All other conditions of the subject remain the same.

Respectfully,

A handwritten signature in blue ink that reads "Dolly Daniels".

Dolly Daniels, Senior Buyer
City of Grand Junction, Colorado